



Pacific Coast Well & Pump Inc.

2415 San Ramon Valley Blvd., Ste.#4-440, San Ramon, CA 94583
 510-581-6000 • pacific_coast_wp@att.net
 Lic. # 810579 A-General Engineering, C-57 Well Drilling.



INSPECTION REPORT and FLOW TEST

TEST DATE: 16-12-20

Customer: John Smith

LOCATION: Street Address
City, CA

Contact: John
555-555-5555

APN# 25-25-25-000

WELL INSPECTION CONDUCT BY: David James

STATIC WATER LEVEL	25
DEPTH OF WELL	121
DEPTH TO PUMP	115
CASING	6 inch PVC
PUMP SIZE/TYPE	1 1/2 HP SUB
MOTOR SIZE/TYPE	1 1/2 HP SUB
VOLTAGE/AMP DRAW	230v / 10.2 AMPS
PUMP SAVER	no
PRESSURE TANK SYST.	n/a
VARIABLE SPEED	n/a
PRESSURE SETTINGS	n/a
BOOSTER PUMP/TYPE	Goulds 35VBK
VARIABLE SPEED	no
PRESSURE SETTINGS	n/a
VOLTAGE/AMP DRAW	230v / 13.0 AMPS
STORAGE TANK/TYPE	5000 gallon Poly
FLOAT CONTROLS/TYPE	low-cut off switch

No repairs needed at the time of inspection. Well performed consistently at 12.3 gallons per min, and may perform at a higher rate with a larger pump.

Length of test hours 4 hours

This Well produces 12.3 gallons per min.

Recovered

START TIME	WATER LEVEL	GPM
8:15		
8:30	24.6	12.6
8:45	25	12.3
9:00	25	12.3
9:15	25	12.3
9:30	25	12.3
9:45	25	12.3
10:00	25	12.3
10:15	25	12.3
10:30	25	12.3
10:45	25	12.3
11:00	25	12.3
11:15	25	12.3
11:30	25	12.3
11:45	25	12.3
12:00	25	12.3
12:15	25	12.3
12:30	25	12.3
12:45		
1:00		
1:15		
1:30		
1:45		
2:00		
2:15		
2:30		
2:45		
3:00		
3:15		
3:30		
3:45		
4:00		
4:15		
4:30		
4:45		
5:00		